

Brush Creek 175 Road Fish Passage Project

Q & A

1. Is the material being supplied for “engineered fill”?

The selected contractor will provide all imported rock, there is not an owner provided rock source for aggregate based, stream channel, engineered fill or rock slope protection.

2. Where is the “supplied by owner” aggregate base located?

The selected contractor will provide all imported rock, there is not an owner provided rock source for aggregate base, stream channel, engineered fill or rock slope protection.

3. Is the “imported rock slope protection” located at the same quarry?

The selected contractor will provide all imported rock, there is not an owner provided rock source for aggregate based, stream channel, engineered fill or rock slope protection.

4. Is the owner wanting to keep the culverts?

No, the owner does not wish to salvage the culverts, they are encased in concrete.

5. Is it expected the unclassified ex material is reusable for streambed substrate if screened?

It is unknown if unclassified excavation will be salvageable for any of the rock materials, that will be evaluated and determined by the owner provided geotech representative.

6. Page S-1 alludes to the select structural fill could be sorted out of the unclassified borrow too? The spec says WSDOT BC.

Structural fill is to be furnished by the selected contractor; it will not come from unclassified borrow.

7. Where is the waste area for the unclassified borrow?

Unclassified borrow will be graded into adjacent hillslopes at the project site or adjacent to.

8. What is the scope of bid item 17, miscellaneous construction?

Miscellaneous construction - is on an as needed basis for any hourly work beyond the scope of work, estimated to not exceed 16 hours.